

DISTRICT WATER TESTING LABORATORY, MANSA
Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa
dwtlmansa@gmail.com

To,

SAHIBZADA JUJHAR SINGH PUBLIC SEN.SEC.SCHOOL
KOT DHARMU, TEHSIL & DISTT. MANSA

No.: DWTL/MNS/2627/00192 Dated : 06/06/2026


Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. SJSPS/SGPC/2026-27/6162 Dated: 04/06/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 05/06/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Mansa

D/A : Test Report


Principal
SJS Public Sen. Sec. School
Kotdharu


Authorized Signatory
For, District Water Testing Laboratory
Mansa

DISTRICT WATER TESTING LABORATORY, MANSA
Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa
dwtlmanasa@gmail.com



TC-11388

TEST REPORT

Name & Address of Customer : SAHIBZADA JUJHAR SINGH PUBLIC SEN.SEC.SCHOOL KOT DHARMU, TEHSIL & DISTT. MANSA			Customer Reference No.		No : SJSPS/SGPC/2026-27/6162 Dated : 04/06/2026	
			Sample Submitted by		MR JARNAIL SINGH	
			Date of Sample Receipt		05/06/2026	
			Analysis Starting Date		05/06/2026	
			Analysis completion Date		06/06/2026	
Discipline :			Group: Water			
ULR No.:	TC113862600000267F		Sample Type :		Water	
Test Report No.:	DWTL/MNS/2627/00192		Date of Issue :		06/06/2026	
Registration no.:	DWTL/MNS/REG2627/00734		Condition of Sample :		Unsealed	
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)		Quantity/Type of Bottle:		1000 ml / Transparent Plastic Bottle	
Scheme/Source:	Not Mentioned(Not Mentioned)		Location/Depth :		SAHIBZADA JUJHAR SINGH PUBLIC SEN.SEC.SCHOOL / NA	
Village :	Kot Dharmu		Habitation :		Kot Dharmu	
Block:	Jhunir		District :		Mansa	
Latitude :	Not Mentioned		Longitude:		Not Mentioned	

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.51@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	NT	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	59	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	68	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	94	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	24.04	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	8.26	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	16.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

(Signature)
Principal
SJS Public Sen. Sec. School
Kotdharmu

(Signature)
Ms. Komal Sharma
Quality Manager
Authorized Signatory

For, District Water Testing Laboratory
Mansa

End of the Test Report